

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. MEMO/SCHOOL/028/25-26

Dated: 11/06/2025

It is certified that an inspection team headed by Dr. SHAILENDRA YADAV WITH TE

(Name of Officers with designation) from PHC MARIAMU.....PHED

inspected the JMS SENIOR SEC. SCHOOL CHAKRABATI MARIAMU JAUNPUR

(Name & Address of the school) on 11/06/2025.....(date of inspection) and on the basis of

Water Test Report (Attached) bearing no. RWT/VNS/392/25-26 dated 09/06/2025

of REGIONAL WATER ANALYSIS BHAGWANPUR VNS Lab) certified that


the JMS SENIOR SEC. SCHOOL.....(Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till One Year 11/06/2026



Signature with Seal: अधिशासी अभियन्ता

Name खण्ड कार्यालय

Designation उत्तर प्रदेश / कृषि विभाग (मृदा)

Name & Address of the Office / Department जौनपुर

To THE MANAGER

JMS SENIOR SEC. SCHOOL CHAKRABATI MARIAMU JNP.
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



REGIONAL WATER ANALYSIS LABORATORY, UTTAR PRADESH JAL NIGAM
Bhagwanpur, Varanasi – Uttar Pradesh 221005



*** TEST REPORT ***

Name & Address of Customer: J.M.S. SENIOR SECONDARY SCHOOL, CHAKRABIYA, MARIAHU, JAUNPUR, U.P.		Customer Reference No.	No: 392/VNS/09 Dated: 09/06/2025
		Sample Submitted by	RAJKUMAR YADAV
		Date of Sample Receipt	09/06/2025
		Analysis Starting Date	09/06/2025
		Analysis completion Date	09/06/2025
Discipline: Chemical Testing		Group: Water	
Test Report No.:	RWTL/VNS/392/25-26	Date of Issue:	09/06/2025
Registration no.:	RWTL/SNG/2526/REG392	Condition of Sample:	Unsealed
Source:	NA	Quantity/Type of Bottle:	1000ml / Amber Colored Glass Bottle
Scheme:	NA	Location/Depth:	RO plant J.M.S. SENIOR SECONDARY SCHOOL, CHAKRABIYA, MARIAHU, JAUNPUR, U.P./ NA
Village:	CHAKRABIYA	Habitation:	NA
Block: -	MARIAHU	District:	Jaunpur
Latitude:	NA	Longitude:	NA

Sample Type: Treated Water

Sr. No	Parameter	Result	As per 15-10500:2012 (2 nd Rev.)		Unit	Reference Method:
			Acceptable Limit	Permissible Limit		
1	pH	7.90	6.5-8.5	No Relaxation		IS 3025 (Part 11-1993) Electrometric Method
2	Colour	01	5	15	Hazen	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Disagreeable		IS 3025 (Part 5 -2018) (Second Revision)
4	TDS	220	500	"2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
5	Turbidity	1.12	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
6	Alkalinity	120	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
7	Hardness	180	200	600	mg/l	IS 3025 (Part 21- 2019) EDTA Method
8	Calcium	86	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
9	Magnesium	27	30	100	mg/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method
10	Chloride	80	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition:

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed)
5. * Value not available or test not performed for this parameter.

TRUE COPY

Dr. Ramesh Yadav
Quality Manager
Authorized Signatory
For, Regional Water Analysis,
Laboratory Jal Nigam Varanasi- UP.

End of the Test Report